



BV LCIE
CHINA
Number

N°1866AS03OMK27547

ATTESTATION of conformity with European Directives

Product: Grid-connected photovoltaic inverter
Reference Omnixsol-50k-TL3-H
Issued to Omnik New Energy Co., Ltd.
Address No.63 Weixin Road, SIP215122 Suzhou China
Manufacturer Omnik New Energy Co., Ltd.
Technical characteristics See below table

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

<i>Standards</i>	<i>Report number</i>	<i>Report date</i>
EN 62109-1:2010 EN62109-2:2011	OMK-18JA0366FTSP-1 OMK-18JA0366FTSP-2	2018-03-27

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China),), March 27th, 2018.



Dio zhang
Operation Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务(上海)有
限公司

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com

Version 3/2016.02.19



LCIE

BV LCIE
CHINA
Number

N°1866AS03OMK27547

MPP DC voltage range [V]..... :	200-1000
Max Input DC voltage [V]..... :	1100
Input DC current [A]..... :	22*4(Max.)
Output AC voltage [V] :	3~, 500V a.c., 50/60Hz
Output AC current [A]..... :	60,8(Max.)
Output power [kVA]..... :	47,5(Normal), 52,5(Max.)

Shanghai (P.R. China),), March 27th, 2018.



Dio zhang
Operation Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务(上海)有限公司

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email:contact@cn.bureauveritas.com

Version 3/2016.02.19