





Product Service

# CERTIFICATE

No. Z2 084937 0029 Rev. 01

## Model(s):

CS6U-xxxP, (xxx=255 to 375 in step of 5W)  
 CS6X-xxxP, (xxx=255 to 350 in step of 5W)  
 CS6U-xxxP-WS, (xxx=255 to 350 in step of 5W)  
 CS6X-xxxP-WS, (xxx=255 to 350 in step of 5W)  
 CS6K-xxxP, (xxx=200 to 310 in step of 5W)  
 CS6P-xxxP, (xxx=200 to 285 in step of 5W)  
 CS6K-xxxP-SD, (xxx=200 to 285 in step of 5W)  
 CS6P-xxxP-SD, (xxx=200 to 285 in step of 5W)  
 CS6K-xxxP-WS, (xxx=200 to 285 in step of 5W)  
 CS6P-xxxP-WS, (xxx=200 to 285 in step of 5W)  
 CS6X-xxxP-FG, (xxx=290 to 350 in step of 5W)  
 CS6X-xxxP-FG1, (xxx=290 to 350 in step of 5W)  
 CS6K-xxxP-FG, (xxx=245 to 300 in step of 5W)  
 CS6K-xxxP-FG1, (xxx=245 to 300 in step of 5W)  
 CS6K-xxxP-FG3, (xxx=245 to 300 in step of 5W)  
 CS3U-xxxP, (xxx=310 to 385 in step of 5W)  
 CS3K-xxxP, (xxx=250 to 320 in step of 5W)  
 CS3U-xxxP-FG, (xxx=310 to 370 in step of 5W)  
 CS3K-xxxP-FG, (xxx=250 to 310 in step of 5W)  
 CS3K-xxxP-FG1, (xxx=250 to 310 in step of 5W)  
 CS3W-xxxP, (xxx=380 to 425 in step of 5W)  
 CS3L-xxxP, (xxx=315 to 350 in step of 5W)  
 CS3U-xxxPB-FG, (xxx=320 to 395 in step of 5W)  
 CS3U-xxxPB-AG, (xxx=320 to 395 in step of 5W)  
 CS3K-xxxPB-FG, (xxx=265 to 325 in step of 5W)  
 CS3K-xxxPB-AG, (xxx=265 to 325 in step of 5W)  
 CS6K-xxxPB-FG, (xxx=255 to 300 in step of 5W)  
 xxx is standing for rated output power at STC

## Parameters:

Construction:	Framed or frameless, with Junction box, Cable and Connectors.
Application Class:	Class A
Maximum System Voltage:	1000 V DC or 1500 V DC
Fire Safety Class:	Class C or Class A
PID test condition:	-1000V or -1500V or +1500V, 96 Hours, 60°C, 85 % RH
PID testing method is according to IEC TS 62804-1:2015	

## Tested according to:

IEC 61215(ed.2)  
 IEC 61730-1(ed.1);am1;am2  
 IEC 61730-2(ed.1);am1  
 PPP 58042B:2015

## Production Facility(ies):

084938

TÜV SÜD  
 ZERTIFIKAT ◆ CERTIFICATE ◆ 認證書 ◆ CERTIFICADO ◆ CERTIFICAT