



Product Service

CERTIFICATE

No. Z2 103499 0001 Rev. 01

Model(s):

IBS72MxxxW (xxx=325-390 in step of 5W)
 IBS60MxxxW (xxx=275-325 in step of 5W)
 IBS54MxxxW (xxx=245-290 in step of 5W)
 IBS48MxxxW (xxx=220-260 in step of 5W)
 IBS42MxxxW (xxx=190-225 in step of 5W)
 IBS36MxxxW (xxx=165-195 in step of 5W)
 xxx is standing for rated output power at STC

Parameters:

Safety Class:	Class II
Max. System Voltage:	1500V DC
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China
Construction:	Framed, with Junction box, cable and connector.
Fire Safety Class	Class C according to UL790

Tested according to:

IEC 61215-1(ed.1)
 IEC 61215-1-1(ed.1)
 IEC 61215-2(ed.1)
 IEC 61730-1(ed.2)
 IEC 61730-2(ed.2)

Production Facility(ies):

093848

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
 ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT